




Test Report

Nº B26-12-CX-06E

Type tests

TEST OBJECT	Gray color electrical insulating matting. Class 0.
DESIGNATION	TTCL0
MANUFACTURER	SIBILLE FAMECA ELECTRIC
CUSTOMER	SIBILLE FAMECA ELECTRIC RN 7 Sud. ZI Les Plaines N°17, 26780 Malataverne. France
STANDARD	IEC 61111:2009
RECEPTION DATE	March 1 st , 2013
TEST DATE	4 th -15 th March , 2013
ISSUE DATE	19 th March, 2013

Test chief	Head of Electrical Equipment Laboratory
  <p>is document is a copy in pdf of the original Report, as requested by the client</p>	
Estibaliz Montes	Luis Martínez

* The present report refers only and exclusively to the sample tested and at the moment and conditions in which the measures were made.

The partial reproduction of the present document is categorically forbidden without the permission in writing of TECNALIA Research & Innovation

13. SUMMARY

Visual and measurement tests Classification Composition Dimensions - length and width Dimensions - thickness Workmanship and finish Marking	CORRECT
Mechanical tests Puncture resistance Slip resistance	CORRECT
Dielectric tests Proof test Withstand test	CORRECT
Ageing test	CORRECT
Thermal tests Flame retardant test Low temperature test	CORRECT
Acid resistance	CORRECT
Oil resistance	CORRECT